Aboveground Storage Tank Compliance Seminar

August 16, 2016





By

Sam Wilkes, MS, PWS

Geo-Environmental Department Manager

sam.wilkes@terradon.com

304-729-9119



Summary of Presentation

- Summary of Annual Qualified Inspections
- Summary of O&M Inspections
- Record Keeping Methods



Summary Annual Qualified Inspections

Inspections PE/API	3 Years (Level 1)	5 Years (Level 2)
1st Qualified Inspection	Within 180 days of	Within 180 days of
not already PE/API inspected, under INTERPRETIVE	August 1, 2016	August 1, 2016
RULE (47CSR 62)	(January 28, 2017)	(January 28, 2017)
	XXX	January 1, 2018
		January 1, 2019
	January 1, 2018	January 1, 2020
Owner Inspections intervening years	January 1, 2019	January 1, 2021
PE/API Qualified Inspection	January 1, 2020	January 1, 2022
Fit For Service	January 1 Annually	
	January 1, must submit recommended	
Fit, but needs repairs	repair schedule	
Deficient	Taken out of services for repairs	
Annual WVDEP Certifications filed Electronic	January 1 Annually	
Submission System (ESS)		







Annual Inspection Form Summary

- Secondary Containment
- Tank Foundation/Support Condition
- Tank Construction Material
- Tank External Coating
- Tank Shell Condition
- Tank Manways, Piping and Equipment
- Tank Roof
- Venting
- Electrical Equipment
- Poly or Fiberglass Rapped Plastic Tank Inspection
- Owner Inquiry
 - Leak Detection Method(s) being used
 - Vent Testing as required by manufacturer
 - Secondary Containment sufficiently impervious (72 hours)
 - Cathodic Protection tested yearly



Fit, Fit with Repairs, or Deficient?










Summary of O&M Inspections

Item	Level 1 AST	Level 2 AST
Title 47 CSR Series 63 AST	Effective Date August 1, 2016	
O&M Secondary Containment Inspection (47-63-5)	14 days	1 month
Secondary Containment (sufficiently impervious, 72 hours)	x	x
Release, spill, overflow, or leak	x	х
Deterioration, accumulation of product, or water	X	х
Drains secure and closed	x	x
Rain water must not exceed 10% capacity	x	x
Retain inspection documentation	12 cont	inuous months







Repairs







Summary of O&M Inspections

	Level 1	Level 2
AST Visual Inspection to 1st Isolation Point	1 month	1 month
Monitor Leak Detection Methods (Section 10.3)	x	x
Visual Leak Detection (10.3.c) Double Bottomed designed to channel fluids to an		
observation area	X	X
Interstitial Monitoring (10.3.g)	X	X
Leak Detection Deficiencies	June 30, 2017	June 30, 2018
Records must contain: Monitors Name, Monitoring Method(s), Monitoring Date, Results	x	x
Coatings (rust, blisters, peeling, cracking, coating bond failure)	X	X
Malfunctioning or deficient equipment <i>Critical</i> repairs	30 days	30 days
Retain Inspection Documentation	12 continuous months	







Recordkeeping Methods

Inspection Documents	Minimum consecutive 12 months
Customized Hard Copy Paper	Binder to be kept at the facility
Electronic Inspection Sheets in Word	Electronic Files to be kept at the facility
Electronic Inspection Sheets in Excel	Spreadsheet style initial and comment area
Electronic files converted to PDF with electronic signature	
May be scanned with real signature and kept in PDF format	
Ultimately long term files can be kept in database or GIS formats	
Annual Inspection forms kept with a photo log and WVDEP certification and maintenance log, if necessary	







Discussion and Questions

Sam Wilkes

Geo-Environmental Department Manager

304-729-9119

sam.wilkes@terradon.com

